



**Rauland Telecenter® 1100**  
**System Manuals**

---

**RAULAND-BORG CORPORATION • 3450 West Oakton Street, Skokie, Illinois 60076-2951 • (847) 679-0900**

---

## Contents

### KI-1801 Consists of the Following Manuals:

---

Programming .....	KI-1629B
Operation .....	KI-1682
Rauland Telecenter 1100: 2524 Controller Installation .....	KI-1628B
Operation of 2524 Controller/Master Clock .....	KI-1630
AC-Cord Installation .....	KI-1660
CTL1 Telephone Interface Module Planning and Installation (with PLA1 Planning) .....	KI-1681C

Installers: ***CAUTION!***

Read ***all*** of these manuals before installing the equipment.

Installers and Service People:

CMOS is susceptible to static discharge: **Work with a grounding Strap.**